



**The certificate verifies that:**

*The Access Panel Company Ltd  
The Old Water Works  
Winterton Road  
Scunthorpe,  
North Lincolnshire  
DN15 0BA*

**Has had tested or assessed for Acoustic Reduction the following product:**

**Description:** *Premium Range Access Panel, Pivot Hinged.*

**Date:** *04/11/2009*

**Acoustic Reduction:** *34db*  
(Extrapolated Elemental Methodology)

**Orientation:** *Wall or Ceiling*

**UKAS Testing Procedures:** *Yes*

**Test Code:** *H16596EA*

**Test Lab:** *The Building Test Centre*

**Acoustic Reduction:** *45db*  
(Achieved in Tested Surrounding)

**Report Number:** *BTC16596AA*

**Methodology:** *BS EN ISO 140-3:1995*

*Externally audited quality management procedures guarantee full traceability of the manufacturing process for fire rated product specifications.*

