



**The certificate verifies that:**

*The Access Panel Company Ltd  
The Old Water Works  
Winterton Road  
Scunthorpe, North Lincolnshire DN15 0BA*

**Has had tested or assessed for Fire the following product:**

**Description:** *Tile Access Panel with 1 Locking Point and Piano Hinge.*

**Date:** *20/12/2002*

**Size:** *1200 x 600mm*

**Result Integrity:** *133 minutes no failure*

**Orientation:** *Wall*

**Result Insulation:** *N/A*

**Duration:** *133 minutes*

**Report Number:** *Chilt/RF02128B*

**Test Lab:** *Chiltern International Fire*

**UKAS Testing Procedures:** *Yes*

**Methodology:** *BS476:Part22:1987*

*Where sizes differ from the tested or assessed sizes the company will consider solutions to the same tested constructions or commission further assessments or tests when necessary.*

*Externally audited quality management procedures guarantee full traceability of the manufacturing process for fire rated product specifications.*

**BS EN ISO 9001:2008 Certificate Number: GB18691**

