



The certificate verifies that:

*The Access Panel Company Ltd
The Old Water Works
Winterton Road
Scunthorpe,
North Lincolnshire
DN15 0BA*

Has had tested or assessed for Acoustic Reduction the following product:

Description: *Loft Hatch, Pin Hinged.*

Date: *04/11/2009*

Acoustic Reduction: *38db*
(Extrapolated Elemental Methodology)

Orientation: *Wall or Ceiling*

UKAS Testing Procedures: *Yes*

Test Code: *H16596MA*

Test Lab: *The Building Test Centre*

Acoustic Reduction: *49db*
(Achieved in Tested Surrounding)

Report Number: *BTC16596AA*

Methodology: *BS EN ISO 140-3:1995*

Externally audited quality management procedures guarantee full traceability of the manufacturing process for fire rated product specifications.

